



1
S-1
ROOF PLAN
scale: 3/32" = 1'-0"



2
S-1
SECTION
scale: 3/4" = 1'-0"

RTU INSTALLATION NOTES

- ALL STRUCTURAL SAWN LUMBER SHALL BE SPECIES GROUP "D", STRESS GRADE NO. "2", NO MORE THAN 15 PERCENT OF THE LUMBER SUPPLIED SHALL BE OF A GRADE LOWER THAN SPECIFIED.
- ALL STRUCTURAL SAWN LUMBER SHALL BE IN ACCORDANCE WITH THE REQUIREMENTS OF C.S.A. STANDARD 086 AND THE REQUIREMENTS OF THE CURRENT EDITION OF THE NATIONAL BUILDING CODE OF CANADA.
- ALL FRAMING AND CONNECTION OF MEMBERS, INCLUDING STRUCTURAL COMPOSITE LUMBER PRODUCTS ETC, TO COMPLY WITH THE REQUIREMENTS OF PART 9 OF THE MANITOBA BUILDING CODE.
- EXISTING ROOF STRUCTURE HAS BEEN REVIEWED FOR THE EXISTING LOADS AND ADDITIONAL LOADS DUE TO NEW RTU, AMU AND ASSOCIATED SNOW BUILD-UP LOADS, ACCORDING TO FIGURE G-8 OF THE USER'S GUIDE OF NBC (2010) STRUCTURAL COMMENTARIES, AND HAS BEEN FOUND IN CONFORMITY WITH THE REQUIREMENTS OF "PART 4 - STRUCTURAL DESIGN" OF MBC 2011 EDITION. ANY APPLICABLE SNOW LOAD BUILD-UP HAS BEEN SHOWN ON THE PART ROOF FRAMING PLAN.
- NEW RTU WEIGHT 1325#
- FOR CONSTRUCTION November 23, 2015



ISSUED FOR CONSTRUCTION		NOV 23, 2015
NO.	DESCRIPTION	DATE
REVISIONS		
BY		

Frovich & Associates		120 St. Anne's Road Winnipeg, MB R2M 2Z2 (204) 254-0666
Job Title		CARBONE RESTAURANT NEW ROOF TOP UNIT
Unit		UNIT B - 680 ST. ANNE'S RD. WINNIPEG, MB.
Sheet Title		STRUCTURAL
Drawn DLL	Date NOV 23, 2015	Drawing No. S-1
Checked	Scale	
File No. 67915	AS NOTED	